

**Mandatory Language for Monitoring and Reporting Violation
Failure to Submit a Surface Water Monthly Operating Report (SWMOR)
SURFACE WATER MONITORING, ROUTINE MAJOR**

WINKLER WSC, PWS ID **TX1750023** has violated the monitoring and reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Title 30, Texas Administrative Code (30 TAC), Section 290, Subchapter F. Public water systems that treat surface water and/or ground water under the direct influence of surface water are required to submit monthly operating reports with operational data of the treatment, disinfection and quality of the water provided to their customers.

This/**These** violation(s) occurred in the monitoring period(s) (36 (0200)) MAY 2025 PWS failed to monitor / report all CT data needed to evaluate the level of microbial inactivation for microbial inactivation for 2 days.

Results of regular monitoring are an indicator of whether or not your drinking water is safe. We did not complete all monitoring and/or reporting for surface water constituents, and therefore TCEQ cannot be sure of the safety of your drinking water during that time.

We are taking the following action to address this matter: We are submitting the SWMOR reports to TCEQ, but they have been turned in late.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact:

Water System Official: Jeremy Crocker

Area code + phone number: 903-275-9996

Posted /Delivered on: 10/27/2025